

E.W. Howell Co., LLC

113 Crossways Park Drive

Woodbury, NY 11797

Phone: 516-921-7100

Fax: 516-921-7920

REQUEST FOR INFORMATION

No. 00016

TITLE: Liner Panel Building 600A

DATE: 9/11/2009

PROJECT: BNL CCWF-II

JOB:

TO: Attn: Alan Raphael
Brookhaven National Laboratory
Brookhaven Sciences Associates, LLC
Project Modernization Office
Upton, NY 11973-5000
Phone: 631-344-5854

STARTED:

COMPLETED:

REQUIRED: 9/18/2009

WORK

IMPACT: Unknown

SCHEDULE

IMPACT: Unknown

COST

IMPACT: Unknown

QUESTION:

9/11/2009

Liner Panel Building 600A

The specification calls out for an interior liner panel. The existing building 600A has the metal panels screwed into the grits from the outside which indicates a sandwich construction. Please advise if you want to match the existing or the specified system.

CC: File

PROPOSED SOLUTION:

ANSWER:

MATCH EXISTING WALL SYSTEM - Intent is that exterior of building extensions are matched for color and profile. Either system is acceptable.
AR 9/21/09



Requested By: E.W. Howell Co., LLC

Date: 9/16/09

Signed: _____
Lauren Bergin